



ALSEAL MARKETING SDN. BHD. Co.No.: 200301022720 (625140-D)

Lot PT 2291, Jalan Kampung Baru, Kampung Baru Sg. Buloh, 47000 Sungai Buloh, Selangor.

Tel: +603-6143 3808 **Fax:** +603-6157 8002 **Email:** info@alsealmarketing.com

Website: www.alsealmarketing.com

Our reference: 16/D20/LTR/Y394

16 April 2020

Dear Valued Customer / Business Partners,

RE: “ALSEAL” AS-1120 Ultra Flex Gap Sealant - Product Performance

This is to confirm that the product performance of **“ALSEAL” AS-1120 Ultra Flex Gap Sealant** has been tested by ISO/IEC 17025 accredited independent third-party testing labs. The following standards were used to test the performance of AS-1120:

Test standard	Description	Report No.
ASTM C920	Standard Specification for Elastomeric Joint Sealants	7191234501-MEC20/01-ED (221418386)

Conclusion

AS-1120 is classified as a **Type S** (single-component sealant), **Grade NS** (non-sag sealant), **Class 25** ($\pm 25\%$ movement), Use **NT** (non-traffic), **M** (mortar) according to ASTM C920.

Should you require further information concerning the above product, please do not hesitate to contact us.

Thank you.

Yours sincerely,

For Alseal Marketing Sdn. Bhd.

Prepared by: Yap Wai Hoong
(R&D Chemist)

Verified by: Alex Ng
(General Manager (Technical))