



**ALSEAL MARKETING SDN. BHD.** Co.No.: 200301022720 (625140-D)

No. 86, Jalan Industri 3/3, Rawang Integrated Industrial Park, 48000 Rawang, Selangor.

Tel: +603-6094 2088 Fax: +603-6099 2930 Email: info@alsealmarketing.com

Website: www.alsealmarketing.com

Our reference: 04/F20/LTR/Y407

4<sup>th</sup> June 2020

Dear Valued Customer / Business Partners,

**RE: “ALSEAL” AS-1130 Fast Drying Gaps Sealer - Low-VOC Compliant**

This is to confirm that the volatile organic compound (VOC) content for **“ALSEAL” AS-1130 Fast Drying Gaps Sealer** has been tested by an independent third party testing lab. The VOC content determination was conducted as per the requirement of South Coast Air Quality Management District (SCAQMD) rule 1168.

SCAQMD rule 1168 states that USEPA Method 24 (Determination of Volatile Matter Content, Water Content, Density Volume Solids, and Weight Solids of Surface Coating) shall be used to determine the VOC content of adhesives and sealants. This reference method is **widely accepted worldwide** for the VOC content determination.

VOC Determination Method	Maximum limit	Results	Report no.
USEPA Method 24 and SCAQMD Method 304-91	50 g/L (All other architectural sealants)	36.97 g/L	CCN19100238H10-3

**Conclusion**

Based on the results shown above, AS-1130 is able to meet the **low-VOC contact adhesive** requirement.

With the low VOC feature, the use of AS-1130 could contribute to **Leadership in Energy and Environmental Design (LEED)** credits under the **IEQc4.1: Low-Emitting Materials - Adhesives and Sealants** credit category. For Malaysian market, AS-1130 could contribute to the **Green Building Index (GBI)** credits.

Should you require further information concerning the above product, please do not hesitate to contact us.

Thank you.

Yours sincerely,

For Alseal Marketing Sdn. Bhd.

Prepared by: Yap Wai Hoong  
(R&D Chemist)

Verified by: Alex Ng  
(General Manager (Technical))