



Testing. Advising. Assuring.

**EWFA CERTIFICATE OF ASSESSMENT** **CERTIFICATE No: SFC FAS180452c.1** **Page 1 of 2**

Report Sponsor	Certificate Issue Date	Product Details
Aleal Marketing Sdn, Bhd. Lot 2291, Jalan Kampung Baru, Kg. Baru Sungai Buloh, 47000 Selangor De, Malaysia.	15 October 2018	Aleal AS-202 Fire Retardant Silicone sealant

**Introduction**  
 The element of construction described below was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced Assessment Report(s) or Regulatory Information Report(s) for the complete description of the assessment construction.

Referenced Assessment Report	Test Methods	Report Issue Date	Report Validity Date
FAS180452c.1	AS 1530.4:2014	15 October 2018	31 October 2023

**Description of Assessment Product and Performance**

The scope of this assessment is limited to the fire resistance of Aleal AS-202 Fire Retardant Silicone sealant protecting control joints in walls and floors if tested in accordance with AS1530.4 – 2014 and assessed in accordance with AS4072.1-2005.

The proposed construction shall be as tested in EWFA 53596800d.2, EWFA 43878800g.1 and EWFA 53596801d.1 in accordance with EN-1366-4:2006 and shall be assessed as if tested in accordance with AS 1530.4-2014 and assessed to AS 4072.1-2005 for wall and floor constructions and subject to following variations:

- Floors made from a minimum 250 mm thick concrete.
- Walls constructed from minimum 250 mm thick masonry, concrete or AAC.
- Walls with sealant at the exposed and unexposed side, exposed side only and unexposed side only.

**Conditions/ Validity**

- THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Australia Pty Ltd	
<b>Address</b>	Unit 2, 409-411 Hammond Road, Dandenong, Melbourne, VIC 3175	
<b>Phone / Fax</b>	T: +61 (0)2 8270 7600 / F: +61 (0)2 9299 6076	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	www.exova.com	
<b>Authorisation</b>	Prepared By:  Tanmay Bhat	Reviewed By:  Hon Wong

**Description of assessed product and performance (Continued)**