

Our reference: 25/H22/LTR/Y506

25<sup>th</sup> August 2022

**Dear Valued Customer / Business Partners,**

**RE: AS-207 Weatherseal Sealant Statement of Product Compliance**

This letter is to elaborate on AS-207 Weatherseal Sealant contributing to Leadership in Energy and Environmental Design (LEED) v4.1 credit. The EQ Credit: Low-Emitting Materials requires 75 % of adhesives and sealants to meet the volatile organic compound (VOC) emissions evaluation and 100 % of adhesives and sealants to meet the VOC content evaluation.

For VOC emissions, the product is to be tested as per the California Department of Public Health (CDPH) Standard Method v1.2-2017. The product must comply with the VOC allowable concentration listed in Table 4-1 of the standard method. The total VOC (TVOC) after 14 days is required to be reported in ranges as specified in the standard method.

The parameters for the modelling scenario are as follows:

Parameter	Value	
	Standard School Classroom	Standard Private Office
Volume	231 m <sup>3</sup>	30.6 m <sup>3</sup>
Air change rate	0.82 hr <sup>-1</sup>	0.68 hr <sup>-1</sup>
Estimated exposed area	1.62 m <sup>2</sup>	0.21 m <sup>2</sup>

The TVOC of AS-207 Weatherseal Sealant after 14 days is as follow:

Elapsed exposure hour after 10 days conditioning	Predicted Air Concentration	
	Standard School Classroom	Standard Private Office
96	0.5 mg/m <sup>3</sup> or less	0.5 mg/m <sup>3</sup> or less

Formaldehyde content was not detected for all results (refer to Table 2 and Table 3 of test report 7191274108-CHM22-06-MA-AD2-CR1).



**ALSEAL MARKETING SDN. BHD.** Co.No.: 200301022720 (625140-D)

No. 86, Jalan Industri 3/3, Rawang Integrated Industrial Park, 48000 Rawang, Selangor.

**Tel:** +603-6094 2088 **Fax:** +603-6099 2930 **Email:** info@alsealmarketing.com

**Website:** www.alsealmarketing.com

---

For VOC content, the product is to be tested as per the South Coast Air Quality Management District (SCAQMD) Rule 1168. The VOC content of AS-207 Weatherseal Sealant is 45.54g/L (refer to certificate CCN22020050H03-0). This is below the VOC limit (50g/L) under "All Other Architectural Sealants" category.

Based on the test result of VOC emission (test report 7191274108-CHM22-06-MA-AD2-CR1) and VOC content (certificate CCN22020050H03-0), AS-207 Weatherseal Sealant complies to requirements of LEED v4.1 EQ Credit: Low-Emitting Materials.

Should you require any additional information, please do not hesitate to contact us.

Thank you.

Yours sincerely,

For Alseal Marketing Sdn. Bhd.

A handwritten signature in black ink, consisting of a large loop followed by a horizontal stroke and a small dash.

---

Prepared by: Yap Wai Hoong  
(R&D Chemist)

A handwritten signature in black ink, featuring a large, sweeping loop that encircles the name 'Alex Ng'.

---

Verified by: Alex Ng  
(General Manager (Technical))

**TEST REPORT: 7191274108-CHM22-06-MA-AD2-CR1**  
**(Re-issue dated: 22 AUG 2022)**

Date: 12 JUL 2022

Tel: +65 6973 6176

Client's Ref: 221420148

Email: Sihai.Li@tuvsud.com

**Note:** This report is issued subject to the Testing and Certification Regulations of the TÜV SÜD Group and the General Terms and Conditions of Business of TÜV SÜD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.



PSB Singapore

**Add value.  
Inspire trust.**

**SUBJECT**

Evaluation of "AS-207" product sample in accordance with CDPH/EHLB/Standard Method Version 1.2

**CLIENT**

Alseal Marketing Sdn. Bhd.  
No. 86, Jalan Industri 3/3,  
Rawang Integrated Industrial Park  
48000 Rawang,  
Selangor DE

**DESCRIPTION OF SAMPLE**

Two 300 ml tubes of sample labelled as followed were received on 17 Feb 2022. Sample was submitted by Vital Technical Sdn Bhd:

<b>Product Name</b>	Weatherseal Sealant
<b>Model / Series</b>	AS-207
<b>Product Type</b>	Sealant

**DATE OF ANALYSIS**

21 May 2022 – 06 Jul 2022

**Amendment history**

This test report 7191274108-CHM22-06-MA-AD2-CR1 was amended on 22 Aug 2022 from test report 7191274108-CHM22-06-MA-AD2. Under "Note", the issuance date of the test report no. 7191274108-CHM22-06-MA was amended from "06 JUL 2022" to "12 JUL 2022".



Laboratory:  
TÜV SÜD PSB Pte. Ltd.  
15 International Business Park  
TÜV SÜD @ IBP  
Singapore 609937

Phone : +65-6778 7777  
E-mail: info.sg@tuvsud.com  
<https://www.tuvsud.com/sg>  
Co. Reg : 199002667R

Regional Head Office:  
TÜV SÜD Asia Pacific Pte. Ltd.  
15 International Business Park  
TÜV SÜD @ IBP  
Singapore 609937  
**TÜV®**

# TEST REPORT: 7191274108-CHM22-06-MA-AD2-CR1

12 JUL 2022

(Re-issue dated: 22 AUG 2022)



PSB Singapore

## Note:

1. No physical test sample was submitted for testing for the specific product which is the subject of this additional test report.
2. Test results stated in this additional test report was based exclusively on the test results of a past submitted and tested sample reported in Test report No. 7191274108-CHM22-06-MA dated 12 JUL 2022.
3. This additional test report was issued on the basis of the declaration by the Customer that the specific product which is the subject of this additional test report is exactly the same as the original sample provided for Test report No. 7191274108-CHM22-06-MA dated 12 JUL 2022 in terms of technical specification and performance.
4. Details of the product, including name, brand, article number and any technical specification are solely provided by the Customer. No verification has been done by TUV SUD PSB Pte Ltd whether such details are true and correct.
5. Details of Customer's declaration are as follows :

Company Name :

Vital Technical Sdn. Bhd.

Address :

No. 93, Jalan Industri 3/3, Rawang Integrated Industrial Park,  
48000 Rawang, Selangor DE, Malaysia

Name of Authorised person :

Mr Cheong Chee Leong

Contact Telephone / Email address :

+603-60942088 / cl.cheong@vitaltechnical.com

**METHOD OF TEST****1. Emission Test**

The following emission tests were conducted according to CDPH/EHLB/Standard Method Version 1.2 – *Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers*

- 1) Total Volatile Organic Compounds (TVOC) Emission Rate
- 2) Formaldehyde Emission Rate

**Emission Test Condition**

- 1) Chamber Volume: about 1m<sup>3</sup>
- 2) Temperature: 23°C
- 3) Relative Humidity: 50%
- 4) Air Exchange Rate: n=1 (air change rate per hour in the chamber)
- 5) Chamber Loading Ratio: 0.3-1.0 m<sup>2</sup>/m<sup>3</sup> (total exposed surface area of the test specimen divided by the net air volume of the emission test chamber)
- 6) Air Velocity: 0.1 m/s to 0.3 m/s (over the surface of the test specimen)

Note: Chamber Loading ratio for the tested sample: 0.007 m<sup>2</sup>/m<sup>3</sup>

**2. Sampling, Desorption, Analysis**

- 1) For analysis, the air was sampled using constant flow rate pumps, equipped with absorbent containing Tenax TA to trap VOCs. (sampling and assay carried out according to ISO 16000-6 / ASTM D5116).
- 2) In addition, the air was sampled using constant flow rate pumps, provided with absorbent containing di-nitrophenylhydrazine (DNPH) grafted silica cartridge to trap aldehydes. (sampling and assay performed according to ISO 16000-3)
- 3) The Tenax samples were then desorbed by Automated Thermal Desorber System and then analyzed by Gas Chromatography coupled with Mass Spectrometry (ATD-GCMS).
- 4) The samples on DNPH cartridge were then desorbed to form the stable compound hydrazone, which was then assayed by Liquid Chromatography (HPLC) with UV / Diode Array Detector.

**METHOD OF TEST** (cont')**3. Calculation of Results****Air Concentration Determinations**

## Emission Factor Calculations

$$EF = C \times (N/L)$$

EF = emission factor ( $\mu\text{g}/\text{m}^2\cdot\text{hr}$ ) or ( $\mu\text{g}/\text{unit}\cdot\text{hr}$ )

C = chamber concentration ( $\mu\text{g}/\text{m}^3$ )

N = chamber air exchange rate ( $\text{hr}^{-1}$ )

L = product loading ( $\text{m}^2/\text{m}^3$ )

The model measurements were made with the following assumptions: air within open office areas of the building is well-mixed at the breathing level zone of the occupied space; environmental conditions are maintained at 50 % relative humidity and 23°C (73°F); there are no additional sources of these pollutants; and there are no sinks or potential re-emitting sources within the space for these pollutants.

The predicted exposure concentrations ( $C_{P,t}$ ) ( $\mu\text{g}/\text{m}^3$ ) are calculated from the modelled emission factors as:

$$C_{P,t} = EF_{m,t} \left( \frac{A}{V} \right) \left( \frac{1}{N} \right)$$

where,

$C_{P,t}$  = predicted exposure concentration at time t ( $\mu\text{g}/\text{m}^3$ )

$EF_{m,t}$  = modelled emission factor at time t ( $\mu\text{g}/\text{m}^2\cdot\text{hr}$ ) or ( $\mu\text{g}/\text{unit}\cdot\text{hr}$ )

A = product area exposed in room ( $\text{m}^2$  or unit)

V = room volume ( $\text{m}^3$ )

N = room air change per hour ( $\text{hr}^{-1}$ )

The model was set as Private Office and/or Standard Classroom scenario as defined in Table 4-4 and Table 4-5 with reference to California Department of Public Health (CDPH) *Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers V 1.2* (2017). The following parameters are used for estimating VOC air concentrations at 336 hours for the modelling scenarios.

Parameter	Units	Value	
		Standard Classroom	Private Office
Volume	$\text{m}^3$	231	30.6
Air Change Rate	1/h	0.82	0.68
Loading Factor *	$\text{m}^2/\text{m}^3$	0.007	0.007
Estimated Exposed Area	$\text{m}^2$	1.62	0.21

\* Based on Clause 4.2.2 of EN16516 - Construction products: Assessment of release of dangerous substances – Determination of emissions into indoor air. Loading factor for very small surfaces, e.g. sealants.

**TEST REPORT: 7191274108-CHM22-06-MA-AD2-CR1**

12 JUL 2022

(Re-issue dated: 22 AUG 2022)



PSB Singapore

**RESULTS****Table 1. Summary of TVOC Chamber Concentrations, Emission Factors and Predicted Air Concentrations for "AS-207"**

Elapsed Exposure Hour after 10 Days Conditioning *	Chamber Concentrations ( $\mu\text{g}/\text{m}^3$ )	Emission Factor ( $\mu\text{g}/\text{m}^2\cdot\text{hr}$ )	Predicted Air Concentration ( $\mu\text{g}/\text{m}^3$ )	
			Standard Classroom	Private Office
0 (Background)	BQL	BQL	-	
24	542.7	48840.1	413.5	505.4
48	526.1	47346.2	400.8	490.0
96	522.9	47059.0	398.4	487.0

\* Exposure hours are nominal ( $\pm 1$  hour)BQL = Below quantifiable level of  $0.02 \mu\text{g}$  based on a standard 12 L air collection volume**Table 2. Summary of Formaldehyde Chamber Concentrations, Emission Factors and Predicted Air Concentrations for "AS-207"**

Elapsed Exposure Hour after 10 Days Conditioning *	Chamber Concentrations ( $\mu\text{g}/\text{m}^3$ )	Emission Factor ( $\mu\text{g}/\text{m}^2\cdot\text{hr}$ )	Predicted Air Concentration ( $\mu\text{g}/\text{m}^3$ )	
			Standard Classroom	Private Office
0 (Background)	BQL	BQL	--	--
24	BQL	BQL	--	--
48	BQL	BQL	--	--

\* Exposure hours are nominal ( $\pm 1$  hour)BQL = Below quantifiable level of  $0.05 \mu\text{g}$  based on a standard 30 L air collection volume

# TEST REPORT: 7191274108-CHM22-06-MA-AD2-CR1

12 JUL 2022

(Re-issue dated: 22 AUG 2022)



PSB Singapore

## RESULTS (cont'd)

**Table 3. Chamber Concentrations, Emission Factors and Predicted Air Concentrations of Target CRELs Compounds for "AS-207" at 96 Hours Following 10 Day of Conditioning.**

Cas Number	Target CRELs Compound Name	Chamber Concentrations (µg/m³)	Emission Factor (µg/m²·hr)	Predicted Air Concentration (µg/m³)		Half CREL (µg/m³)
				Standard Classroom	Private Office	
75-07-0	Acetaldehyde	7.5	678.6	5.7	7.0	70
71-43-2	Benzene <sup>†</sup>	BQL	BQL	--	--	1.5
75-15-0	Carbon Disulfide	BQL	BQL	--	--	400
56-23-5	Carbon Tetrachloride	BQL	BQL	--	--	20
108-90-7	Chlorobenzene <sup>†</sup>	BQL	BQL	--	--	500
67-66-3	Chloroform	BQL	BQL	--	--	150
106-46-7	Dichlorobenzene (1,4-) <sup>†</sup>	BQL	BQL	--	--	400
75-35-4	Dichloroethylene (1,1)	BQL	BQL	--	--	35
68-12-2	Dimethylformamide (N,N) <sup>†</sup>	BQL	BQL	--	--	40
123-91-1	Dioxane (1,4-) <sup>†</sup>	BQL	BQL	--	--	1500
106-89-8	Epichlorohydrin <sup>†</sup>	BQL	BQL	--	--	1.5
100-41-4	Ethylbenzene <sup>†</sup>	BQL	BQL	--	--	1000
107-21-1	Ethylene Glycol	BQL	BQL	--	--	200
110-80-5	Ethylene Glycol Monoethyl Ether	BQL	BQL	--	--	35
111-15-9	Ethylene Glycol Monoethyl Ether Acetate	BQL	BQL	--	--	150
109-86-4	Ethylene Glycol Monomethyl Ether	BQL	BQL	--	--	30
110-49-6	Ethylene Glycol Monomethyl Ether Acetate	BQL	BQL	--	--	45
50-00-0	Formaldehyde	BQL	BQL	--	--	9
110-54-3	Hexane (n-) <sup>†</sup>	BQL	BQL	--	--	3500
78-59-1	Isophorone	BQL	BQL	--	--	1000
67-63-0	Isopropanol <sup>†</sup>	BQL	BQL	--	--	3500
71-55-6	Methyl Chloroform	BQL	BQL	--	--	500
75-09-2	Methylene Chloride	BQL	BQL	--	--	200
1634-04-4	Methyl t-Butyl Ether <sup>†</sup>	BQL	BQL	--	--	4000
91-20-3	Naphthalene <sup>†</sup>	BQL	BQL	--	--	4.5
108-95-2	Phenol <sup>†</sup>	BQL	BQL	--	--	100
107-98-2	Propylene Glycol Monomethyl Ether	BQL	BQL	--	--	3500
100-42-5	Styrene <sup>†</sup>	BQL	BQL	--	--	450
127-18-4	Tetrachloroethylene <sup>†</sup>	BQL	BQL	--	--	17.5
108-88-3	Toluene <sup>†</sup>	BQL	BQL	--	--	150
79-01-6	Trichloroethylene <sup>†</sup>	BQL	BQL	--	--	300
108-05-4	Vinyl Acetate	BQL	BQL	--	--	100
108-38-3 /95-47-6 /106-42-3	Xylenes <sup>†</sup>	BQL	BQL	--	--	350

\* Indicates Wiley ver. 8.0 best library match only based on retention time and mass spectral characteristics

† Denotes quantified using authentic standard curve. Other VOCs quantified relative to toluene

BQL = Below quantifiable level of 2.0 µg/m³



# TEST REPORT: 7191274108-CHM22-06-MA-AD2-CR1

12 JUL 2022

(Re-issue dated: 22 AUG 2022)



PSB Singapore

## RESULTS (cont'd)


**Table 4. Chamber Concentrations, Emission Factors and Predicted Air Concentrations of Identified Individual Organic Compounds (VOCs) for "AS-207" at 96 Hours Following 10 Day of Conditioning for Standard Classroom and Private Office scenario.**


Cas Number	Compound Identified	Chamber Concentrations ( $\mu\text{g}/\text{m}^3$ )	Emission Factor ( $\mu\text{g}/\text{m}^2\cdot\text{hr}$ )	Predicted Air Concentration ( $\mu\text{g}/\text{m}^3$ )		Half CREL ( $\mu\text{g}/\text{m}^3$ )
				Standard Classroom	Private Office	
78-93-3	2-Butanone	8.9	798.0	6.8	8.3	not listed
96-29-7	2-Butanone, Oxime	328.4	29556.4	250.2	305.8	not listed
100-52-7	Benzaldehyde	2.6	232.7	2.0	2.4	not listed
98-83-9	alpha-Methylstyrene	2.3	208.9	1.8	2.2	not listed
556-67-2	Cyclotetrasiloxane, Octamethyl	16.3	1470.7	12.4	15.2	not listed
100-51-6	Benzyl Alcohol	5.0	446.8	3.8	4.6	not listed
541-02-6	Cyclopentasiloxane, Decamethyl	34.2	3080.1	26.1	31.9	not listed
540-97-6	Cyclohexasiloxane, Dodecamethyl	46.5	4184.5	35.4	43.3	not listed
77-68-9	Propanoic acid, 2-methyl, 3-hydroxy-2,2,4-trimethylpentyl ester	2.9	264.5	2.2	2.7	not listed
107-50-6	Cycloheptasiloxane, Tetradecamethyl	19.4	1742.8	14.8	18.0	not listed
844-51-9	2,5-Cyclohexadiene-1,4-dione, 2,5-diphenyl	7.7	692.8	5.9	7.2	not listed

\* Indicates Wiley ver. 8.0 best library match only based on retention time and mass spectral characteristics

† Denotes quantified using authentic standard curve. Other VOCs quantified relative to toluene

BQL = Below quantifiable level of  $2.0 \mu\text{g}/\text{m}^3$

  
**MS LOO SHIRLYN**  
 CHEMIST

  
**DR LI SIHAI**  
 AVP / SENIOR CHEMIST  
 MICROCONTAMINATION DIAGNOSIS  
 CHEMICAL & MATERIALS

# TEST REPORT: 7191274108-CHM22-06-MA-AD2-CR1

12 JUL 2022

(Re-issue dated: 22 AUG 2022)




PSB Singapore

Please note that this Report is issued under the following terms :

1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
2. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, 15 International Business Park TÜV SÜD @ IBP Singapore 609937.
6. The tests carried out by TÜV SÜD PSB and this report are subject to TÜV SÜD PSB's General Terms and Conditions of Business and the Testing and Certification Regulations of the TÜV SÜD Group.

Effective 26 January 2021



### CERTIFICATE OF ANALYSIS

ALSEAL MARKETING SDN. BHD.  
No. 86, Jalan Industri 3/3,  
Rawang Integrated Industrial Park,  
48000 Rawang, Selangor DE

Tel : +603-60942088

Attn :

Fax :

Certificate No : CCN22020050H03-0  
Sample Received Date : 17-Feb-2022  
Analysis Start Date : 04-Mar-2022  
Complete Analysis Date : 07-Mar-2022  
Date Issued : 07-Mar-2022

Sample Description : One sample of sealant  
Product name: Weatherseal Sealant  
Product code: AS-207  
Brand: Alseal

Analysis Results :

PARAMETER	ANALYSIS RESULTS	UNIT	STANDARD METHOD / TECHNIQUE / EQUIPMENT USED
VOC	45.54	g/L	USEPA method 24 under SCAQMD Rule 1168 (All other architectural sealants, <50g/L)

<sup>1</sup>denotes Externally Provided and Accredited

<sup>2</sup>denotes Externally Provided but not Accredited

For Chemistry Testing :

**ND** denotes **Not Detected**, (< **Numeric number**) denotes below limit of quantification

For Microbiology Testing :

(< **Numeric number**) denotes **Not Detected** and below limit of detection

**Remark :** The result reported are based on the calculation from Total Volatile Compound, Density testing parameter and information declaration of exempted solvent and water provided by customer.



Cheng Pui Wah  
Senior Chemist  
B.Sc.(Hons),  
L/1828/6037/11