



**ALSEAL MARKETING SDN. BHD.** Co.No.: 200301022720 (625140-D)

No. 86, Jalan Industri 3/3, Rawang Integrated Industrial Park, 48000 Rawang, Selangor.

Tel: +603-6094 2088

Fax: +603-6099 2930

Email: info@alsealmarketing.com

Website: www.alsealmarketing.com

Our reference: 20/J20/LTR/Y416

20<sup>th</sup> October 2020

Dear Valued Customer / Business Partners,

**RE: “ALSEAL” AS-208 Glass & Metal Sealant - Product Performance**

This is to confirm that the product performance of “ALSEAL” AS-208 Glass & Metal Sealant has been tested by ISO/IEC 17025 accredited independent third-party testing labs. The following standards were used to test the performance of AS-208:

Test standard	Description	Report No.
ASTM C920	Standard Specification for Elastomeric Joint Sealants	7191241115- MEC20/02A-ED & 7191241115- MEC20/2B-KSY

**Conclusion**

AS-208 is classified as a **Type S** (single-component sealant), **Grade NS** (non-sag sealant), **Class 25** ( $\pm 25\%$  movement), Use **NT** (non-traffic), **A** (aluminium), **G** (glass) according to ASTM C920.

Should you require further information concerning the above product, please do not hesitate to contact us.

Thank you

Yours sincerely,

For Alseal Marketing Sdn. Bhd.

Prepared by: Yap Wai Hoong  
(R&D Chemist)

Verified by: Alex Ng  
(General Manager (Technical))