



ALSEAL MARKETING SDN. BHD. (625140-D)

LOT PT 2291, JALAN KAMPUNG BARU, KAMPUNG BARU SUNGAI BULOH,
47000 SUNGAI BULOH, SELANGOR.

TEL: 603-6157 9698, 603-6157 6398

FAX: 603-6157 8002

EMAIL: Info@alsealmarketing.com

WEBSITE: <http://www.alsealmarketing.com>

GST No.: 001625505792

Our reference: 06/C18/LTR/Y242

6th March 2018

Dear Valued Customer / Business Partners,

RE: "ALSEAL" AS-208C Glass & Metal Sealant - Low-VOC Compliant

This is to confirm that the volatile organic compound (VOC) content for **"ALSEAL" AS-208C Glass & Metal Sealant** has been tested by an independent third-party testing lab. The VOC content determination was conducted as per the requirement of South Coast Air Quality Management District (SCAQMD) rule 1168.

SCAQMD rule 1168 states that USEPA Method 24 (Determination of Volatile Matter Content, Water Content, Density Volume Solids, and Weight Solids of Surface Coating) shall be used to determine the VOC content of adhesives and sealants. This reference method is **widely accepted worldwide** for the VOC content determination.

VOC Determination Method	Maximum limit	Results	Report no.
USEPA Method 24	250 g/L (architectural sealants)	88.10 g/L	CCN17010154H01-0

Conclusion

Based on the results shown above, AS-208C is able to meet the **low-VOC architectural sealant** requirement.

With the low VOC feature, the use of AS-208C could contribute to **Leadership in Energy and Environmental Design (LEED)** credits under the **IEQc4.1: Low-Emitting Materials - Adhesives and Sealants** credit category. For Malaysian market, AS-208C could contribute to the **Green Building Index (GBI)** credits.

Should you require further information concerning the above product, please do not hesitate to contact us.

Thank you.

Yours sincerely,
For Alseal Marketing Sdn. Bhd.

Prepared by: Yap Wai Hoong
(R&D Chemist)

Verified by: Alex Ng
(Technical Manager)