



ALSEAL MARKETING SDN. BHD. (625140-D)

LOT PT 2291, JALAN KAMPUNG BARU, KAMPUNG BARU SUNGAI BULOH,
47000 SUNGAI BULOH, SELANGOR.

TEL: 603-6157 9698, 603-6157 6398

FAX: 603-6157 8002

EMAIL: Info@alsealmarketing.com

WEBSITE: <http://www.alsealmarketing.com>

GST No.: 001625505792

Our reference: 08/H18/LTR/Y286

8th August 2018

Dear Valued Customer / Business Partners,

RE: “ALSEAL” AS-4028 Instant Grab Adhesive - Low-VOC Compliant

This is to confirm that the volatile organic compound (VOC) content for **“ALSEAL” AS-4028 Instant Grab Adhesive** has been tested by an independent third-party testing lab. The VOC content determination was conducted as per the requirement of South Coast Air Quality Management District (SCAQMD) rule 1168.

SCAQMD rule 1168 states that USEPA Method 24 (Determination of Volatile Matter Content, Water Content, Density Volume Solids, and Weight Solids of Surface Coating) shall be used to determine the VOC content of adhesives and sealants. This reference method is **widely accepted worldwide** for the VOC content determination.

VOC Determination Method	Maximum limit	Results	Report no.
USEPA Method 24 under SCAQMD Rule 1168	250 g/L (All Other Adhesives)	55.26 g/L	CCN18070086H03-0

Conclusion

Based on the results shown above, AS-4028 is able to meet the **low-VOC architectural sealant** requirement.

With the low VOC feature, the use of AS-4028 could contribute to **Leadership in Energy and Environmental Design (LEED)** credits under the **IEQc4.1: Low-Emitting Materials - Adhesives and Sealants** credit category. For Malaysian market, AS-4028 could contribute to the **Green Building Index (GBI)** credits.

Should you require further information concerning the above product, please do not hesitate to contact us.

Thank you.

Yours sincerely,
For Alseal Marketing Sdn. Bhd.

Prepared by: Yap Wai Hoong
(R&D Chemist)

Verified by: Alex Ng
(Technical Manager)

**ACUMEN SCIENTIFIC SDN. B BHD.** (514926-V)Wisma Texchem, Lot 808 & 809, Jalan Subang 5, Taman Perincindustrialian Subang,
47610 Subang Jaya, Selangor Darul Ehsan, Malaysia.

TEL: +603-56345618 FAX: +603-56345619

EMAIL: inquiry@acumen.com.my WEBSITE: www.acumennen.com.my

CERTIFICATE OF ANALYSISALSEAL MARKETING SDN. BHD.
Lot 2291, Jalan Kampung Baru,
Kg. Baru Sungai Buloh, 47000 Selangor DE.Certificate No : CCN18070086H03-0
Sample Received Date : 13-Jul-2018
Complete Analysis Date : 27-Jul-2018
Date Issued : 27-Jul-2018

Tel : +603-6157 9698

Fax :

Attn :

Sample Description : Product Name: Instant Grab Adhesive
Product Code: AS-4028
Brand: Alseal

Analysis Results :

PARAMETER	ANALYSIS RESULTS	UNIT	STANDARD METHOD / TECHNIQUE / EQUIPMENT USED
VOC	55.26	g/L	USEPA method 24 under SCAQMD Rule 1168 (All Other Adhesives, <250g/L)

ND denotes not detected (< **Numeric number**) denotes detection limits

Remark : -

Cheng Pui Wah
Senior Chemist
B.Sc.(Hons),
L/1828/6037/11